



IQRA National University, Peshawar
Department of Electrical Engineering
Spring20
Power Generation
Assignment 1

Name: Talha Khan REG.No: 13845

Question No 1 (CLO -1) 20

A. A 100kVA distribution transformer costs Rs 2,00,000 and has an estimated useful life of 20 years. Find the annual depreciation amount, assuming that the scrap value of the transformer to be Rs 10,000.

B. The average demand of a consumer is 40 A at 230 volts at unity power factor His total energy consumption annually is 10,000 KWh. If the unit rate is Rs 2 per kWh for the first 500hours use of the demand per annum plus Re 1 for each additional units, Calculate the annual bill of the consumer and equivalent flat rate.

Question No 2 (CLO-2) 10

A: power station has to supply load as follows:

Timings	KW
11 pm to 5 am	500
5 am to 6 am	750
6 am to 7 am	1000
7 am to 9 am	2000
9 am to 12 noon	2500
12 Noon to 1 pm	1500
1 pm to 5 pm	2500

Page (1)

Talha Khan 13845

Q 1 (a):

Given that:

$$P = 200,000$$

$$S = 10,000$$

$$N = 20 \text{ years}$$

Depreciation $D = ?$

$$D = (P - S) / n$$

$$D = \frac{200,000 - 10,000}{20}$$

$$D = \text{Rs } 9500 \text{ annually.}$$

Q 1 (b): Given:

$$\text{Energy: } E = 10,000 \text{ kWh}$$

$$\text{Current: } I = 40 \text{ A}$$

$$\text{Voltage: } V = 230 \text{ V}$$

Page (2)

The Power demand of consumer
is $P = V_i \cos \phi = 230 \times 40 \times 1$
 $= 9200 \text{ W or } 9.2 \text{ kW}$

Electricity consumption for the first
500 hours is $= 500 \times 9.2$
 $= 4600 \text{ kWh}$

Since the cost of electricity is Rs 2
per kWh of for the consumer has to
pay;

$$5400 \times 1 = \text{Rs } 5400$$

$$\text{Annual bill} = 9200 + 5400$$
$$= 14,600$$

The flat rate equivalent is:

$$14600 / 10,000$$
$$= \text{Rs } 1.46 \text{ per kWh.}$$

Q 2:


Solution:

Energy generated during 24 hours.

$$\begin{aligned} &= (500 \times 5) + (750 \times 1) + (1000 \times 1) \\ &\quad + (2000 \times 2) + (2500 \times 3) + (1500 \times 1) \\ &\quad + (2500 \times 4) + (2000 \times 2) + (2500 \times 2) \\ &\quad + (1000 \times 2) + (500 \times 1) \\ &= 38,750 \text{ kWh} \end{aligned}$$

$$\text{Maximum demand} = 2500 \text{ kW}$$

$$\begin{aligned} \text{Load factor} &= \frac{\text{Energy generated during 24 hours}}{\text{Maximum demand} \times 24 \text{ hours}} \\ &= \frac{38,750}{2500 \times 24} \\ &= 64.7\% \end{aligned}$$



Load curve of a Power Station.

Page (5)

Two sets each of 1000kW capacity

One set of 500kW capacity

The reserve capacity required will correspond to the largest size of the unit in the station.

In this case a set of 1000kW will have to be bought and kept as reserve - The total installed capacity of the station will

$1000 + 1000 + 500 + 1000$ (reserve) i.e. 3500 kW

$$\text{Plant capacity factor} = \frac{\text{Energy produced during 24 hours (kWh)}}{\text{Installed capacity (kW)} \times 24 \text{ hours}}$$

$$= \frac{38,750}{3500 \times 24} = 0.46 \text{ or } 46\%$$

$$= 46\%$$

Page (6)

The capacity of the individual sets is chosen as far as possible to fit approximately the load curve. Next it should be decided how, when and in what sequence the sets should be started and run.

From 11 P.m. to 5 a.m. only 500 kW set is run.

At 5 a.m. the load is expected to increase

The first 1000 kW set is started and paralleled with the 500 kW set, all the load is transferred to the 1000 kW set, and then 500 kW set is stopped.

Thus one set of 1000 kW is run from 5 a.m. to 7 a.m. taking up the necessary load.

Just before 7 a.m. when an increase in load is expected, the second 1000 kW set is started and paralleled with the first one.

Page (7)

From 7 a.m. to 9 a.m. both the 1000 kW sets are running together.

At 9 a.m. still more load is expected, the 500 kW set is started and paralleled with the other sets on the busbars and loaded along with them. Thus at the time of supplying the maximum load b/w 9 a.m. and 12 noon, all the three sets are running on full load. One of the 1000 kW sets is stopped after the load has dropped to 1500 kW.

From 1 p.m. to 5 p.m. this set is run again along with the two other.

At 5 p.m. the load again drops, owing to the working shift shift in industries being over. The load on the 500 kW set is removed and then this set is taken out of commission.

At 7 p.m. the load increase owing to lighting and all the three sets are run until 9 p.m.

Page (8)

At 9pm two set are taken out and only one 1000kw is run until 11pm.

After 11pm only the 500kw set need be run.

At each time of change-over, care should be taken to ensure correct Paralleling and load transfer.

With the operating schedule fixed as above the energy that could have been generated by the capacity of plant running for the scheduled time would be

$$\begin{aligned} & (500 \times 6) + (1000 \times 2) + (2000 \times 2) + (2500 \times 3) \\ & + (1500 \times 1) + (2500 \times 1) + (2000 \times 2) + (2500 \times 2) \\ & + (1000 \times 2) = 39,000 \text{ kWh} \end{aligned}$$

Energy actually produced = 38,750 kWh

Page (9)

$$\text{Plant use factor} = \frac{\text{Energy Produced (kWh)}}{\text{capacity of Plant (kW)} \times \text{Number of hours}}$$

Plant has been in operation

$$= \frac{38,750}{39,000} = 0.994 \text{ or } 99.4\%$$

$$= 99.4\%$$
