

Name :- Ahmad Ali Qazi.

A.D :- 7780

Subject :- Waste Water

Assignment :- 01

Teacher :- Nadeem Ullah.

Date: \_\_\_\_\_

①

## QUESTION :- 1

Briefly describe each one of these parameters?

=> Hydraulic Retention Time

HRT defined as the ratio b/w the reactor volume  $V_r$  feed flow rate, represents the average time  $t_r$  cells & substrates stay inside the reactor. HRT is very important parameters for Hydrogen & methane production in continuous mode. very low HRT concludes the washout of the reactor which means all the active microorganisms escape out from the reactor on the contrary an adequate HRT result in abundant hydrogen and methane yields.

Date: \_\_\_\_\_

②

Low HRT favored the washout of methanogens, guaranteeing the survival of hydrogen producers.

### ⇒ Solid Retention Time:

The solid retention time (SRT) is the time the solid fraction of the waste water spend in a treatment unit. It is quantity of solids maintained in the reactor divided by the quantity of solids coming out of the reactor each day.  $SRT = V \times C_d / Q_{out} \times C_{out}$ .  $C_{out}$  is the solid concentration of the effluent. In a conventional completely mixed or Plug flow reactor, the HRT equals the SRT.

The solids retention time of SRT controls the concentration of bacteria

Date: \_\_\_\_\_

③

through the treatment system.

- \* Smaller reactor size.
- \* Larger separator size.
- \* Reduced sludge production.

QUESTION :- 2

What are the methods used for decoupling SRT from HRT.

Ans:- By decoupling the SRT and HRT, the liquid waste water can be processed faster HRT is the time water is retained within the digester and is equal to reactor volume divided by the average volumetric flow rate. In many instances a short HRT will reduce capital operation cost. There may be some advantages for a simple design generally reliable and easily managed. although modern

Date: \_\_\_\_\_

④

controls permit it hands off management of more complex design that decouple HRT to SRT.

Some of the more common digester types are given below

- \* Continuous stirred tank reactor.
- \* HRT Contact Reactor.
- \* HRT Sequencing Batch reactor.
- \* Plug Flow reactor.
- \* Judiced bed reactor.

X ————— X

Date: \_\_\_\_\_

⑤

## QUESTION:-3

What are the advantages of decoupling SRT from HRT.

Ans: HRT treatment technology has relatively low equipment cost.

⇒ Available HRT treatment system can be applied at small as well as larger scale.

⇒ HRT Process stability can be easily achieved.

⇒ Managment requirement is low.

⇒ off-gas air pollution can be diminated.

⇒ Foaming of surfactant containing waste water can be avoided.

Date: \_\_\_\_\_

⑥

- ⇒ The HRT treatment technology does not require the impact of expensive equipment.
- ⇒ HRT nonbiodegradable organics can be degraded.
- ⇒ Less space is required for an HRT treatment plant compared to an HRT treatment plant.

x \_\_\_\_\_ x